

COMMITTED TO EXCELLENCE

**DATE:** May 6, 2008

**TO:** Dan Van Horne, Principal

**SUBJECT:** Garden Ridge ES - IAQ - Test Results for Room 117

On Friday 4/25, EFI Air Tested Room 117. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 117, was **17.8%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,

Paul

Paul Siddall

Special Projects (IAQ)

Facility Services

469-446-8882