

COMMITTED TO EXCELLENCE

DATE: August 27, 2007

TO: Mike Rogers, Principal

SUBJECT: Bridlewood ES - IAQ - Test Results for Rooms 201,504,506

On Friday 8/17, EFI Air Tested Rooms 201, 504, and 506. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 201, was **0.9%**, Room 504 was **0.0%**, Room 506 was **0.9%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882