

COMMITTED TO EXCELLENCE

DATE: September 18, 2007

TO: Dan Van Horne, Principal

SUBJECT: Garden Ridge ES - IAQ - Test Results for Room 11

On Tuesday 9/11, EFI Air Tested Room 117. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room 117 was **0.5%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882