

COMMITTED TO EXCELLENCE

**DATE:** August 21, 2007

**TO:** Ann Beckel, Principal

**SUBJECT:** Tom Hicks ES - IAQ - Test Results for Room F-123

On Monday 8/13, EFI Air Tested Room F-123. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room F-123, was **1.8%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Special Projects (IAQ)  
469-446-8882