

COMMITTED TO EXCELLENCE

DATE: October 8, 2007

TO: Sherry Wagner, Principal

SUBJECT: Highland Village ES - IAQ - Test Results for Rms H-703 & H-704

On Wednesday 10/3, EFI Air Tested Rooms H-703 & H-704. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in Room H-703 was **30.9%** and Room H-704 was **13.5%** of the outdoor levels. Utilizing this theory, the indoor concentrations are well within the acceptable guidelines for areas with filtered air or air conditioning. If you have any questions, please call me.

Thanks,
Paul

Paul Siddall
Special Projects (IAQ)
469-446-8882