

COMMITTED TO EXCELLENCE

DATE: April 18, 2008

TO: Sherry Wagner, Principal

SUBJECT: Highland Village ES - IAQ - Results for Hallway between 602 & 604

On Wednesday 3/26, EFI Air Tested the Hallway between Rooms 602 & 603. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the Hallway between 602 & 603, was **73.7%**, of the outdoor levels. Based on EFIs observations and data collected from the referenced Hallway at Highland Village ES, it appears that indoor air quality, as it relates to airborne fungi is within recommended guidelines when the close proximity to open doors is taken into account. If you have any questions, please call me.

Thanks,

Paul

Paul Siddall

Special Projects (IAQ)

Facility Services

469-446-8882