

COMMITTED TO EXCELLENCE

**DATE:** January 29, 2008

**TO:** Linda Fontes, Principal

**SUBJECT:** IAQ - B.B. Owen ES - Test Results Room A-9

On Thursday 1/24, EFI Air & Swab Tested the Room A-9. It is typically assumed that indoor spore levels in an area with filtered or air conditioned air, and activity levels associated with schools average 10% to 40% of the outdoor levels. Data from the airborne fungi sampling indicated that the total indoor concentration of mold/fungi in the, was **33.0%**, of the outdoor levels. Utilizing this theory, the indoor concentrations are within the acceptable guidelines for areas with filtered air or air conditioning. But the swab test revealed *Chaetomium/Stachybotrys*. That area will have to be remediated. I will be back in touch with you on a schedule. If you have any questions, please call me.

Thanks,  
Paul

Paul Siddall  
Special Projects (IAQ)  
469-446-8882